



# Aquatic Facility

## Story County Code of Ordinances Chapter 64 Inspection Checklist

**Facility:** Somerset Village Apartments

**Registration #:** SP85-009

**Address:** 2400 Aspen Drive  
Ames, IA 50010

"S" = Satisfactory "U" = Unsatisfactory "N" = Not Applicable

### 64.07 Facility Requirements

**(1) Carbon Monoxide Detectors**

- Detectors in place
- Dated and current

**(2) Designated Signee**

- Current

**(3) Signage**

- Inspection Agency Placard
- Water Test Results (if required)

### 64.08 Aquatic Facility Personnel

**(1) Certified Operator in Charge**

- (a) Training of Personnel
- (b) CPO info current

**(2) Responsible Person**

- (a) Training Provided
- (b) Records Current

### 64.09 Daily Pre-Opening Checklist

- Completed

### Inspection Notes

---

---

---

---

---

---

---

---

---

---

Inspector

Date

**Type**  
<1,500 S/F

**Registration #**  
SP85-009-001

**Surface Area**  
44253

**Volume**  
44253





- 15.4(6)m**: Lifeguard staffing plan, including diagram(s) of zones of surveillance responsibility.
- 15.51(2)e(3)**: Spa temperature recorded when water quality testing is done (104° or less-closures noted when out of temp range).
- 15.51(2)e(1)-(8)**: Spa: ORP and pH at opening and every 2 hours; free Cl (Br) and temperature 2x daily+; combined Cl and cyanuric acid daily; total alkalinity weekly and at each fill; calcium hardness at each fill & bacteria testing monthly
- 15.51(3)b(2)**: Spa drained, cleaned & refilled: 500 gal or less 1x week, 500 -2000 gal 1x every two weeks, more than 2000 gal 1x every three weeks.

**POOL/DECK/SURROUNDING AREA**

- | S   | U                        | N/A                      |
|---|--------------------------|--------------------------|
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| adjusting weirs and removable baskets.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| visible in water less than 8ft deep.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| cleaning.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| portion of pool. Stairs, ladders, recessed steps, or ramps provided in the shallow portion if more than 2 ft deep.      |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| securely anchored.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| the pool wall. The bottom end of ladder is within one inch of the pool wall and covered with a smooth non-metallic cap. |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| slip resistant.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| ladders, ramps, or stairs installed on each side.   |                          |                          |

- | S   | U                        | N/A                      |
|---|--------------------------|--------------------------|
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| securely anchored grab rails or handrails.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| stripe at least 1 inch wide marked at the leading edge of each tread.                                   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| provided.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| compress, self-adhering gauze bandage, disposable gloves & chemical cold compress. Signage if required. |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| with instruction. Signage posted as required.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| the skimming level.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| or broken.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| /GB compliant or the equalizers plugged.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| color.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| slope is marked by a float line with floats spaced no more than 5 ft apart.                             |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| from the other sections by a float line (built or reconstructed since March 10, 1993).                  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| more than 25 ft apart in shallow water.   |                          |                          |

- |   |                          |                          |
|---|--------------------------|--------------------------|
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| around the deep end of swimming pool.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| not permitted (not more than 25 ft apart).  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| and slip resistant.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| have durable and cleanable surface, are free of litter, obstructions & tripping hazards.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| projections or obstructions.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| enclosure has no openings greater than 4 inches.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| building enclosure or combination not less than 4 ft high.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| ground & the top of the lowest horizontal support is at least 45 inches.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| provided for emergency purposes.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| and self-latching (where lifeguards are not provided).  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| high if there are sleeping rooms, hallways, apartments, condominiums or permanent recreation areas used by children that open directly into the swimming pool area. |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| inches high along the full length of each side of the wave pool.  |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| deck equipped with (GFCI) at the outlet or at the breaker serving the outlet.   |                          |                          |
| <input checked="" type="checkbox"/>   | <input type="checkbox"/> | <input type="checkbox"/> |
| indoor or outdoor pools/spas used after sunset (overhead and/or underwater lights) are functional.  |                          |                          |

- | S  | U                        | N/A                      |
|--|--------------------------|--------------------------|
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| posted at two locations (No Diving, No Rough Play, No Running)   |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| accompanied by an adult sign posted at each swimming pool entry where lifeguards are not provided.                   |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| flushing the deck (built or reconstructed since March 14, 1990).   |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| prevents provided on all hose bibs on the deck.  |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| posted to prevent use by the public during general use periods.  |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| swimming pool/spa (built or reconstructed since March 10, 1993).   |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| deep, a 4-inch-wide stripe is marked (floor and wall) at 5 feet depth (built or reconstructed since March 14, 1990). |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| sanitary manner.   |                          |                          |
| <b>SPA</b>   |                          |                          |
| S  | U                        | N/A                      |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| and timer js 10 minutes or less.   |                          |                          |
| <input checked="" type="checkbox"/>  | <input type="checkbox"/> | <input type="checkbox"/> |
| 3in high)  |                          |                          |

**15.52(12)a**: A spa has at least one stairway, ramp, ladder or set of recessed steps designating a point of entry (built or reconstructed since March 14, 1990).

**15.52(12)a(1)2**: Spa stair steps have two hand/grab rails, one on each side of the steps (built or reconstructed since March 10, 1993).

**15.52(12)c**: An emergency shutoff switch near the spa (built or reconstructed since 1999).

#### WADING POOLS

**S**  **U**  **N/A**

**15.4(4)h**: Fully submerged outlets not missing or broken.

**15.4(4)h(1)2**: Fully submerged outlet covers/grates not removable without the use of tools.

**15.4(4)j(4)**: Wading pool within 50 ft of a pool has a barrier at least 36 inches high separating it from the pool or has written alternate management plan on-site.

**15.4(4)(5)**: Gates/doors are self-closing and self-latching (where lifeguards are not provided).

**15.4(6)d(1)**: 'No Lifeguard' (Children must be accompanied by an adult) sign posted at each wading pool entry where lifeguards are not provided.

**15.4(4)j(4)**: Maximum depth of wading pool at each entrance and one location inside enclosure (letters or numbers 3in high).

#### DIVING BOARDS

**S**  **U**  **N/A**

**15.4(4)c(6)**: Diving boards/platforms have slip-resistant surfaces.

**15.4(4)c(8)-(9)**: Diving board handrails and guard rails present and secure.

**15.4(4)c(10)**: Diving board supports, platforms & steps have no obvious visual structural problems.

#### WATER SLIDES

**S**  **U**  **N/A**

**15.4(4)d(5)**: Water slide has a lifeguard (or shallow water guard where applicable) at the top and bottom of slide.

**15.4(4)t(1)**: Water slide support structures are free of obvious structural defects.

**S**  **U**  **N/A**

**15.4(4)o(2)**: The walkable surface of flume is smooth and continuous.

**15.4(4)o(3)**: The walkable surface of flume has no sharp edges within reach of a user while in the proper sliding position.

**15.4(6)e(1)-(6)**: Water slide rules are posted near the slide.

**15.5(17)b(1)**: Plunge pool depth is at least 3 ft and no more than 4 ft.

**15.5(17)b(4)**: Landing area for a water slide is designated by a float line or a painted area.

#### MECHANICAL ROOM

**S**  **U**  **N/A**

**15.4(1)a** & **15.51(1)a**: Filtration system is in good working condition.

**15.4(1)b(1)** & **15.51(1)c**: The recirculation system is operating continuously (except for backwashing or servicing).

**15.4(1)b(1)** & **15.51(1)c**: The circulation system flow meter(s) are functional.

**15.4(1)b(2)** & **15.51(1)b**: Pressure gauges (before and after) filter pump

**15.4(1)c** & **15.51(1)f**: Wastewater and backwash is discharged through an air break or air gap.

**15.4(1)d(1)** & **15.51(1)g(1)**: Water supplied to a pool/spa is discharged to the system through an air gap or a reduced principle backflow device.

**15.4(1)d(2)** & **15.51(1)g(2)**: Vacuum breaker backflow preventers provided on hose bibs in mechanical room.

**15.4(1)e(1)** & **15.51(1)h(1)**: Electric water heaters have UL seal.

**15.4(1)e(2)** & **15.51(1)h(2)**: Gas-fired heaters have AGA seal and equipped with a pressure relief valve.

**15.4(1)e(3)** & **15.51(1)h(3)**: Fuel-burning water heaters are vented to the outside.

**15.4(1)e(4)** & **15.51(1)h(4)**: Rooms with fuel-burning equipment has opening(s) to the outside for providing combustion air.

**15.4(2)g**: Knowledgeable person in testing water/operating water treatment equipment available when pool is open for use.

**15.4(2)f(1)-(3)** & **15.51(2)f(1)-(3)**: A swimming pool/spa facility has water testing equipment for free chlorine & combined chlorine, or total bromine; pH; total alkalinity; calcium hardness; & cyanuric acid.

**15.4(2)f(4)-(5)** & **15.51(2)f(4)-(5)**: ORP/pH controller with numerical analog or digital display

**15.4(3)a(1)** & **15.51(3)a(1)**: Continuous disinfection feed equipment installed and operational.

**15.4(3)a(2)** & **15.52(11)h**: Continuous pH chemical feed equipment installed and operational (built or reconstructed since July 1, 1998).

**15.4(3)b(2)**: A vacuum cleaning system is provided.

**15.4(6)j** & **15.51(5)j**: A schematic drawing of the recirculation system is posted or clear labeling of piping with flow direction and water status (unfiltered, treated, backwashed).

**S**  **U**  **N/A**

**15.4(4)a(2)** & **15.51(4)a(2)**: Swimming pool/spa chemicals properly stored & handled.

**15.4(4)a(4)** & **15.51(4)a(4)**: Chemical storage containers clearly labeled.

**15.4(4)a(5)** & **15.51(4)a(5)**: A chemical hazard warning placed at the entrances to rooms where chemical are used or stored.

**15.4(4)h(3)** & **15.51(4)f(4)**: A pool/spa with a single submerged outlet that is not unlockable is equipped with a SVRS.

**15.4(4)m(2)2** & **15.51(4)j(4)2**: Underwater lights more than 15 V equipped with a GFCI.

**15.5(11)g**: Sodium hypochlorite tanks larger than 55 gallons have secondary containment (built or reconstructed since May 4, 2005).

#### CHLORINE GAS

**S**  **U**  **N/A**

**15.4(4)n(1)1**: Chlorine gas room has an exhaust system.

**15.4(4)n(1)2**: An air intake provided near the ceiling.

**15.4(4)n(1)3**: The exhaust fan shall be operated from a switch labeled "Chlorine Exhaust Fan" in a nearby location outside the chlorine room or building.

**15.4(4)n(1)4**: Discharge from exhaust system outside of pool enclosure

**15.4(4)n(1)5**: Artificial lighting provided in chlorine room

**15.4(4)n(1)7**: A plastic bottle of commercial strength ammonia solution for leak detection.

**15.4(4)m(2)1**: Chlorine gas cylinders are individually anchored with safety chains or straps

#### BATHHOUSE

**S**  **U**  **N/A**

**15.4(5)**: Showers, dressing rooms & sanitary facilities are clean & free of debris.

**15.4(5)a-b**: Floors slip-resistant and maintained without standing water.

**15.4(5)c**: Carpet not in wet areas of the bathhouse/dressing area.



If any of the conditions identified below occur during operation of the swimming pool or spa, the owner or their representative (i.e. CPO, Lifeguard, Manager, etc.) must immediately close the pool/spa and document the closure in the daily logs in accordance to 641 IAC Chapter 15. The pool or spa must remain closed until proper operating conditions are achieved and recorded in the daily logs.

- The swimming pool shall be closed if the free chlorine measurement is less than 0.6 ppm or the total bromine measurement is less than 1.0 ppm.
- The spa shall be closed if the free chlorine measurement is less than 1 ppm or the total bromine measurement is less than 2.0 ppm.
- The spa shall be closed if the temperature is greater than 104°.
- The swimming pool or spa shall be closed if the free chlorine measurement is greater than 8.0 ppm or the total bromine measurement is greater than 18.0 ppm.
- The swimming pool or spa shall be closed if the ORP is less than 650 mV or greater than 880 mV.
- The swimming pool or spa shall be closed if the pH measurement is less than 6.8 or is greater than 8.2.
- The swimming pool or spa shall be closed if the cyanuric acid measurement is greater than 80 ppm.
- The swimming pool or spa (when the spa agitation system is off) shall be closed if the main drain is not clearly visible. (This can be caused by problems such as poor water clarity, surface reflection, and/or inadequate lighting.)
- The swimming pool or spa shall be closed if submerged suction outlets (drain cover, equalizer cover, feature outlets, etc.) are missing or broken.
- The swimming pool or spa shall be closed when chemical additions are made from the deck for at least one-half hour or until the disinfectant residual returns to acceptable levels
- Two consecutive positive test results for coliform bacteria. (After the first positive result, the local inspection agency office should be contacted, and the pool shall be superchlorinated (the addition of chlorine disinfectant compound to a concentration of at least 10 ppm free chlorine) at the facility's earliest convenience but not to exceed 24 hours. A recheck sample shall be taken once the disinfectant residual returns to acceptable levels. The pool shall be closed if the second sample is positive and may reopen once no coliform bacteria are detected and the above listed requirements are met.

  
Pool/Spa Representative

6-15-22  
Date

  
IDPH Representative

6-15-22  
Date

\*The inspection reviewed the facility in relation to the particular requirements of 641 IAC Chapter 15 identified above. The inspection is limited in scope and time noting observed deficiencies. Deficiencies may have occurred before the inspection, may occur after the inspection, or may not have been directly observable by the inspector at the time of inspection. The inspection in no way waives any of the requirements of 641 IAC Chapter 15 and the facility will be required to correct any deficiencies identified through future inspections. The inspection does not review any other local, state, or federal laws, ordinances, regulations, or requirements that may apply to this facility.

### NOTIFICATION OF DEFICIENCIES AND REQUEST FOR CORRECTIVE ACTION

Enforcement 641.15.6(1351)

A list of the deficiencies that were identified in the inspection report require a Corrective Action Plan. Please respond within **10 days** of receipt of the report to the identified deficiencies by completing a Corrective Action Plan with an explanation of how the deficiencies will be corrected and the timeframe. If a deficiency cannot be completed before you respond, you must set a fixed time for correction. Failure to respond within the required timeframe may result with enforcement action against your facility pursuant to Iowa Code 135I and 641 IAC 15.6.

